







# Pump **Specification**

# 2448LSG/LSGX-Series

# Omnivore® 2 HP Simplex Grinder Packages





### LITERS PER MINUTE




### **ATTENTION**

For pressure sewer applications, verify a Redundant Check Valve Assembly (curb stop and check valve) is installed between the pump discharge and the street main, as close to the public right-of-way as possible, on all installations to protect from system pressures.







# 2448LSG/LSGX-Series Electrical Data

MODEL	НР	VOLTAGE	PHASE	SF	FULL LOAD AMPS	LOCKED ROTOR AMPS	THERMAL OVERLOAD TEMP	STATOR WINDING CLASS	CORD LENGTH [FT]	DISCHARGE	AUTOMATIC
2448LSG202	2	208/230	1	1.0	15	53	105°C	В	25	1-1/4" NPT	YES
2448LSGX202	2	208–230	1	1.0	15	53	135°C	В	25	1-1/4" NPT	YES

# 2448LSG/LSGX-Series Technical Data

		WOUND FIBERGLASS WITH ANTI-FLOTATION FLANGE			
	TANK	STANDARD – FIBERGLASS COVER			
		OPTIONAL – STEEL COVER			
	CAPACITY	TOTAL BASIN VOLUME – <b>94</b> GALLONS / 356 LITERS			
	CAPACITY	PUMP CYCLE – <b>14</b> GALLONS / 53 LITERS			
	GUIDE RAIL	STANDARD – SCHEDULE 40 GALVANIZED			
	GOIDE RAIL	OPTIONAL – SCHEDULE 40 STAINLESS STEEL			
SYSTEM	GUIDE RAIL BASE/DISCONNECT (GR20)	CAST IRON			
λS	INLET HUB	4" WITH FLANGE GASKET AND PIPE SEAL			
	DISCHARGE PIPING	SCHEDULE 80 PVC			
	JUNCTION BOX	NEMA 4X OUTDOOR WITH 6-20R 230V RECEPTACLE			
	ALADAA	NEMA 4X OUTDOOR ALARM WITH			
	ALARM	VISUAL AND AUDIBLE (80 dBi) ALARM			
	WEIGHT	230 LBS / 104 KG			

	_				
-	IMPELLER	300 SERIES STAINLESS STEEL			
	PAINT	POWDER COATING			
	MAX LIQUID TEMP	60°C / 140°F			
	MAX STATOR TEMP	LSG202 – 105°C / 221°F			
	WWW.STATION TENT	LSGX202 – 135°C / 275°F			
	THERMAN OVERNOAD	LSG202 – 105°C / 221°F			
	THERMAL OVERLOAD	LSGX202 – 135°C / 275°F			
	POWER CORD TYPE	SJOOW			
PUMP	MOTOR HOUSING	CLASS 25 CAST IRON			
_	VOLUTE	CLASS 25 CAST IRON			
-	SHAFT	300 SERIES STAINLESS STEEL			
	HARDWARE	STAINLESS			
	O-RINGS	BUNA-N			
	MECHANICAL SEAL	UNITIZED GRAPHITE IMPREGNATED SILICON CARBIDE			
	MIN BEARING LIFE	50,000 HRS			
	CERTIFICATIONS	SSPMA, cCSAus			

# 2448LSG/LSGX-Series Specifications

1.01 GENERAL
The contractor shall provide labor, material, equipment, and incidentals required to provide (QTY) centrifugal grinder pumps a specified herein. The pump models covered in this specification are LSG/LSGX-Series single-phase grinder pumps. The pump furnished for this application shall be model as manufactured by Liberty Pumps.
2.01 OPERATING CONDITIONS
Each submersible pump shall be rated at 2 hp, volts, 1-phase, 60 Hz, 3450 RPM. The unit shall produce GPM at feet of total dynamic head.
The submersible pump shall be capable of handling residential and commercial sewage and grinding it to a fine slurry enabling it to be pumped over long distances in pipelines as small as 1.25" in diameter. The LSG-Series single stage submersible pump shall have a shut-o head of 110 feet and a maximum flow of 50 GPM @ 10 feet of total dynamic head. The LSGX-Series two stage submersible pump shall have a shut-off head of 185 feet and a maximum flow of 38 GPM @ 10 feet of total dynamic head.

The pump shall be controlled with a piggyback style on/off float switch.

#### CONSTRUCTION 3.01

Each centrifugal grinder pump shall be equal to the Control of the Bergen NY. The castings shall be constructed of class 25 cast iron. The motor housing shall be oil-filled to dissipate heat. Air-filled motors shall not be considered equal since they do not properly dissipate heat from the motor. All mating parts shall be machined and sealed with a Buna-N O-ring. All fasteners exposed to the liquid shall be stainless steel. The motor shall be protected on the top side with sealed cord entry plate with molded pins to conduct electricity eliminating the ability of water to enter internally through the cord. The motor shall be protected on the lower side with a dual seal arrangement. The first seal is a double lip seal molded in fluoroelastomer OR Buna-N. The second/main seal shall be a unitized graphite impregnated silicon carbide hard face with stainless steel housings and spring.

The upper and lower bearing shall be capable of handling all radial thrust loads. The lower bearing shall have the additional ability to handle the downward axial thrust produced by the impeller and cutters by design of angular contact roller races. The pump housing shall be of the concentric design thereby equalizing the pressure forces inside the housing, which will extend the service life of the seals and bearings. Additionally there shall be no cutwater in the housing volute in order to discourage the entrapment of flowing debris. The pump shall be furnished with a stainless steel handle having a nitrile grip.

#### **ELECTRICAL POWER CORD**

The submersible pumps shall be supplied with 25 feet of multi-conductor power cord. It shall be cord type SJOOW, capable of continued exposure to the pumped liquid. The power cord shall be sized for the rated full load amps of the pump in accordance with the National Electric Code. The power cable shall not enter the motor housing directly but will conduct electricity to the motor by means of a water tight compression fitting cord plate assembly, with molded pins to conduct electricity. This eliminates the ability for water to enter internally through the cord by means of a damaged or wicking cord.

### 5.01 MOTORS

All motors shall be oil-filled, capacitor start/capacitor run, class B insulated NEMA B design, rated for continuous duty. Since air-filled motors are not capable of dissipating heat as effectively, they shall not be considered equal. At maximum load, the winding temperature shall not exceed 105°C for model LSG and 135°C for LSGX models (unsubmerged). The pump motor shall have an integral thermal overload switch in the windings for protecting the motor. The capacitor circuit shall be mounted internally in the pump and motors shall have an integral solid state starting circuit switch for switching the start winding off.

#### 6.01 BEARINGS AND SHAFT

An upper radial and a lower angular contact ball bearing shall be required. The upper bearing shall be a single ball/race type bearing. The lower bearing shall be an angular contact heavy duty ball/race type bearing, designed to handle axial grinder pump thrust loads. Both bearings shall be permanently lubricated by the oil that fills the motor housing. The bearing system shall be designed to enable proper cutter alignment from shut off head to maximum load at 10 feet of TDH. The motor shaft shall be made of 300 series stainless steel and have a minimum diameter of 0.670".

#### **SEALS** 7.01

The pump shall have a dual seal arrangement consisting of a lower and upper seal to protect the motor from the pumping liquid. The lower seal shall be fluoroelastomer OR Buna-N molded double lip seal, designed to exclude foreign material away from the main upper seal. The upper seal shall be a unitized graphite impregnated silicon carbide hard face seal with stainless steel housings and spring equal to Crane Type T-6a. The motor plate/housing interface shall be sealed with a Buna-N O-ring.

#### 8.01 **IMPELLER**

The impeller shall be an investment cast stainless steel impeller, with pump out vanes on the back shroud to keep debris away from the seal area. It shall be keyed and bolted to the motor shaft.

#### 9.01 **CUTTER MECHANISM**

The cutter and plate shall consist of 440 stainless steel with a Rockwell C hardness of 55-60. The stationary cutter plate shall have specially designed orifices through it, which enable the slurry to flow through the pump housing at an equalized pressure and velocity. The stationary cutter shall consist of V shapes to maximize cutting action and arc shape exclusion slots to outwardly eject debris from under the rotary cutter. The rotary cutter shall have four (4) blades and be designed with a recessed area behind the cutting edge to prevent the accumulation and binding of any material between rotary cutter and the stationary cutter. The cutting system must incorporate close tolerances for optimum performance. Ring or radial cutters, or those that grind on the outside circumference, shall not be considered equal.

#### 10.01 PRESSURE SEWER APPLICATIONS

A redundant check valve assembly consisting of a curb stop and check valve must be installed between the pump discharge and the street main, as close to the public right-of-way as possible, on all pressure (force main) sewer installations to protect from system pressures. The curb stop valve is necessary to isolate the site from the pressure sewer while the check valve provides redundant protection against potentially detrimental backflow. All valves and fittings should be rated for at least 200 PSI service. See Liberty Pumps line of CSV-Series Curb Stop/Swing Check Valve Assemblies and CK-Series Connection Kit.

#### 11.01 CONTROLS

All units shall be supplied with CSA and UL approved automatic wide angle tilt float switches. The switches shall be equipped with a piggyback style plug that allows the pump to be operated manually without the removal of the pump in the event that a switch becomes inoperable.

#### 12.01 PAINT

The exterior of the casting shall be protected with powder coat paint.

#### 13.01 SUPPORT

The pumps shall have cast iron support legs, enabling it to be a freestanding unit. The legs shall be high enough to allow solids and long stringy debris to enter the cutter assembly.

#### 14.01 SERVICEABILITY

Components required for the repair of the pump shall be shipped within a period of 24 hours.

Factory mounted guide rail system with pump suspended by means of bolt-on quick disconnect that is sealed by means of nitrile grommets. The discharge piping shall be Schedule 80 PVC and furnished with a check valve and PVC shut-off ball valve. The tank shall be wound fiberglass or roto-molded plastic. An inlet hub shall be provided with the fiberglass systems.  Stainless steel guide rail  Zinc plated steel guide rail  "diameter of basin size  "distance from top of tank to discharge pipe outlet  Fiberglass cover  Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  Remote outdoor alarm  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL  Pumps shall be manufactured in an ISO 9001 certified facility.	15.01 F	ACTORY ASSEMBLED TANK SYSTEMS WITH GUIDE RAIL AND QUICK DISCONNECT DISCHARGE
Zinc plated steel guide rail  "diameter of basin size  "height of basin size  "distance from top of tank to discharge pipe outlet  Fiberglass cover  Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.		grommets. The discharge piping shall be Schedule 80 PVC and furnished with a check valve and PVC shut-off ball valve. The tank
" diameter of basin size  " height of basin size  " distance from top of tank to discharge pipe outlet  Fiberglass cover  Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Stainless steel guide rail
" height of basin size  " distance from top of tank to discharge pipe outlet  Fiberglass cover  Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Zinc plated steel guide rail
"distance from top of tank to discharge pipe outlet  Fiberglass cover  Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.		" diameter of basin size
Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.		" height of basin size
Structural foam polymer cover  Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.		" distance from top of tank to discharge pipe outlet
Steel cover  Simplex system with outdoor panel and alarm  Separate outdoor alarm  Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Fiberglass cover
Simplex system with outdoor panel and alarm Separate outdoor alarm Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Structural foam polymer cover
Separate outdoor alarm  Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Steel cover
Remote outdoor alarm  16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Simplex system with outdoor panel and alarm
16.01 TESTING  The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Separate outdoor alarm
The pumps shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL		Remote outdoor alarm
and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be run, voltage current monitored, and checked for noise or other malfunction.  17.01 QUALITY CONTROL	16.01 1	ESTING
	and insu	lation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the
Pumps shall be manufactured in an ISO 9001 certified facility.	17.01	QUALITY CONTROL
	Pumps s	hall be manufactured in an ISO 9001 certified facility.
18.01 WARRANTY	18.01 \	VARRANTY
Standard limited warranty shall be 3 years.	Standard	d limited warranty shall be 3 years.