SLOAN.

OPTIONS

Flush Volume

1.0 gpf (3.8 Lpf) (1.0) 0.5 gpf (1.9 Lpf) (0.5) 1.5 gpf (5.7 Lpf) (1.5)

Finish

Polished Chrome (CP) Brushed Stainless (SF) Brushed Nickel (BN) Polished Brass (PB) Graphite (GR)

Water Efficiency

Low Consumption High Efficiency Water Saver

Override

Less (L/OR)

Control Stop

Less (L/STOP) 1" Straight (E) 1"

Vacuum Breaker

Less (XYV)

Bumper

Angle Stop (YO)

Special Features

Carbon Offset (CO) Less Logo (LL)

Compliances & Certifications

ADA Compliant BAA Compliant cUPC Certified UL Certified Satisfies LEED Credits WaterSense Listed cUPC Green Certified BREEAM Water Credit Green Globes Water Credit LEED V4 Water Efficiency Credit

NOTES

For product line drawings, view model-specific spec sheets.

All information contained within this document subject to change



Image for a standard G2 8186 shown

DESCRIPTION

G2 Exposed Sensor Urinal Flushometer

FEATURES

- ADA-compliant flushometer automatically operates by means of a infrared sensor with multiple-focused, lobular sensing fields for high and low target detection
- Fixed metering bypass and no external volume adjustment to ensure water conservation
- Adjustable tailpiece to accommodate different height requirements
- High copper, low zinc brass castings for dezincification resistance
- Available in 0.5 gpf/1.9 Lpf, low consumption (1.0 gpf/3.8 Lpf), water saver (1.5 gpf/5.7 Lpf), and conventional (3.5 gpf/13.2 Lpf) models
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Semi-Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037.

DOWNLOADS

- G2 and ECOS Single Flush Optima Plus Valve Installation Instructions
- G2 Repair and Maintenance Guide
- Control Stop Repair and Maintenance Guide
- Flush Connections Flanges Repair and Maintenance Guide
- Tail Piece Repair and Maintenance Guide
- Sloan Optima Plus Flushometers Repair and Maintenance Guide
- Flushometer Pressure gauges



without notice.

Additional Downloads

VIDEOS

